



**BUREAU
VERITAS**

Industry Division

CERTIFICATE OF INSPECTION NO.: TPI12005-2

Issuing Center : Taipei Taiwan

Supplier/Address : Transworld Steel Enterprise Co.,
Ltd.

No.34, Gongye 14th Rd., Dali

Dist., Taichung City 412, Taiwan

(R.O.C.)

The undersigned, B.H. Juang acting with the scope of General Condition of the industrial Branch of Bureau Veritas, certifies that the supplies

Type: Designation : SERIES 83/88

Type of valve: : 3PCs Socket Welded End Ball Valve (Full
Bore)

Pressure rating: : 1500 WOG (Class #600)

Nominal size: : 2 inch x 1 piece

Material

(a) Body : WCB

(b) Bonnet : WCB

(c) Seat : PTFE

Inspected in Lung-Tan, Taiwan

On 01st Feb. 2012

Has been upon request of : Transworld Steel Enterprise Co., Ltd.

Intended for : Transworld Steel Enterprise Co., Ltd.

Inspected in conformity with the applicable requirements of the valve fire test per API 607, SIXTH EDITION and contractual requirements governing the mission entrusted to Bureau Veritas.

Made In Taipei, Taiwan on 8th Feb. 2012

Signature B.H. Juang

Surveyor to Bureau Veritas



Addition qualification of other valves, covered by the valves tests according API standard 607 6th Editions, 2010.

The qualification of ANSI Class : Class 600; 800; 900

The qualification of Size : 2" and below; 2 1/2"; 3" ; 4"

Manufacturer : Transworld Steel Enterprise Co., Ltd.

Particular mention : The test result of valve fire test is passed
Test report of valve fire test attached